CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/SS/W.No.12/2019-20 Date : 10.02.2020

TEST REPORT ON FINE AGGREGATES (SAND)
IS 383-1970 (RA- 2002)

Client : **Assistant Executive Engineer,** Shettyhalli Sub Division, BBMP, Bangalore.

Agency : **M/s. Shrusti Sampadha,** Contractor, Bangalore.

Name of Work : Providing rain water Harvesting Facilities in ward no.12 Shettyhalli, Shettyhalli Sub division, BBMP, Bangalore.

Date of Testing : 10.02.2020

Material : Sand

Total wt. of aggregates in gms = **1000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Spec.Limits For Zone-II
10	0	0	0	100	100
4.75	89	8.90	8.90	91.1	90-100
2.36	130	13.00	21.90	78.1	75-100
1.18	168	16.80	38.70	61.3	55-90
600 Micron	142	14.20	52.90	47.1	35-59
300 Micron	220	22.00	74.90	25.1	8-30
150 Micron	189	18.90	93.80	6.2	0-10

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಜೆಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550